



FEATURES

- 100% full load burn-in test
- Universal AC input
- Small size and high efficiency
- Conform to EMC EN5502 GB9254
- Built-in EMI filter with tiny ripple
- Comply with the safety standards UL60950 GB4943 EN60850
- Protection: short circuit/over Voltage/over/load temperature

MODEL		12V 5W	
ОИТРИТ	DC VOLTAGE	12V	
	RATED CURRENT	0.42A	
	CURRENT RANGE	0~0.42A	
	RATED POWER	5W	
	RIPPLE& NOISE (MAX.)	150mV	
	VOLTAGE TOLERANCE	±1%	
	SETUP , RISE TIME	1000ms, 30ms/230VAC 1000ms,30ms/115VAC at full load	
	HOLD UP TIME(Typ.)	100ms/230VAC 20ms/115VAC at full load	
INPUT	VOLTAGE RANGE	85 ~ 264VAC	
	FREQUENCY RANGE	47~63Hz	
	POWER FACTOR(Typ.)	PF>0.6/220VAC	
	EFFICIENCY(Typ.)	86%	
	AC CURRENT(Typ.)	0.2A/115VAC 0.15A/230VAC	
	INRUSH CURRENT(Typ.)	cold start 45A/230V	
	SHORT CIRCUIT	protection type: recovers automatically after fault condition is removed	
PROTECTION	OVER LOAD	105~135% hiccup mode, auto-recovery	
PROTECTION	DC ADJ. RANGE	±10% rated output voltage	
	WORKING TEMP	-40°C~+60°C (no frost)	
ENVIRONMENT	WORKING HUMIDITY	20%~90%RH	
	STORAGE TEMP , HUMIDITY	-40°C~85°C/10%~95%RH	
SAFETY&EMC	SAFETY STANDARDS	CE ROHS	
	WITHSTAND VOLTAGE	I/P-O/P: 1.5KVAC/1min, I/P-F/G: 1.5KVAC/1min, O/P-F/G: 0.5KVAC/1min	
	EMC TESTING STANDARD -	EN55015:2006; EN61547:1995+A1:2000;EN61000-3-2:2006	
	LIVIC TESTING STANDARD	EN61000-3-3:1995+A2:2005;EN61347-3-13:2006	

Tel: 086 755 2306 0905 Fax: 086 755 2304 1269 <u>Website: www.xinrealpower.com</u>


Add: 5th Floor, B3 Building, Huafeng Shiji Industrial park, Hangcheng Road, Xixiang, Bao'an district, Shenzhen P.R.C.




15W STANDARI

Mechanical Specification

Terminal Assignment					
Pin No.	Assignment	Pin No.	Assignment		
1	AC/L		DC OUTPUT-V		
2	AC/N		DC OUTPUT+V		
3	≟ FG				
Dimension: 70*	40*30 mm	Carton size: 430*278*227 mm			
Carton Quantity: 10	00PCS/Carton	Weight: 0.1Kg/PCS			





REMARKS:

- 1, The above mentioned data were measured at 230VAC input and 25°C.
- 2, Ripple & noise are measured at 20MHz of bandwidth by using a 12" twisted pair-wire terminated with a 0.1uf & 47uf parallel capacitor.
- **3,** Cut the AC input before checking any mal-phenomenons.
- **4,** Make sure the INPUT&OUPUT were in right situation before connected to power supply.
- 5, Be ware of high power pressure may caused by short circut when installing metal casing products.
- **6,** Please contact us at infor@xinrealpower.com for further solution if any unforeable problem happens.

Tel: 086 755 2306 0905

Fax: 086 755 2304 1269

Website: www.xinrealpower.com

Add: 5th Floor, B3 Building, Huafeng Shiji Industrial park, Hangcheng Road, Xixiang, Bao'an district, Shenzhen P.R.C.