



FEATURES

- •100% full load burn-in test
- Universal AC input
- •Small size and high efficiency
- ●Conform to EMC EN5502 GB9254
- •Built-in EMI filter with tiny ripple
- •Comply with the safety standards UL60950 GB4943 EN60850
- Protection: short circuit/over Voltage/over/load temperature

MODEL		12V 100W	24V 100W	
ОИТРИТ	DC VOLTAGE	12V	24V	
	RATED CURRENT	8.5A	4.5A	
	CURRENT RANGE	0~8.5A	0~4.5A	
	RATED POWER	100W	100W	
	RIPPLE& NOISE (MAX.)	120mVp-p	120mVp-p	
	VOLTAGE TOLERANCE	±1%	±1%	
	SETUP , RISE TIME	1000ms, 20ms/230VAC 1000ms, 20ms/115VAC at full load		
	HOLD UP TIME(Typ.)	30ms/230VAC 25ms/115VAC at full load		
INPUT	VOLTAGE RANGE	85 ~ 264VAC		
	FREQUENCY RANGE	47~63Hz		
	POWER FACTOR(Typ.)	PF>0.6/220VAC		
	EFFICIENCY(Typ.)	85%	86%	
	AC CURRENT(Typ.)	2A/115VAC 1.2A/230VAC		
	INRUSH CURRENT(Typ.)	COLD START 45A		
	SHORT CIRCUIT	protection type: recovers automatically after fault condition is removed		
PROTECTION	OVER LOAD	105~135% hiccup mode , auto-recovery		
PROTECTION	DC ADJ. RANGE	115%~135% Cut off the output , auto-recovery		
ENVIRONMENT	WORKING TEMP	-20°C∼+60°C		
	WORKING HUMIDITY	20%~90%RH		
	STORAGE TEMP , HUMIDITY	-40℃~+85℃,10%~90%RH		
SAFETY&EMC	SAFETY STANDARDS	CE,ROHS		
	WITHSTAND VOLTAGE	I/P-O/P:1.5KVAC I/P-FG:1.5KVAC O/P-FG:0.5KVAC		
	EMC TESTING STANDARD -	EN55015:2006;EN61547:1995+A1:2000;EN61000-3-2:2006;		
		EN61000-3-3:1995+A2:2005;EN61347-1:2001;EN61347-2-13:2006		

Tel: 086 755 2306 0905


Fax: 086 755 2304 1269


Add: 5th Floor, B3 Building, Huafeng Shiji Industrial park, Hangcheng Road, Xixiang, Bao'an district, Shenzhen P.R.C.



Mechanical Specification

Terminal Assignment					
Pin No.	Assignment	Pin No.	Assignment		
1	AC/L	4.5	DC OUTPUT-V		
2	AC/N	6.7	DC OUTPUT+V		
3	≟ FG				
Dimension: 180)*71*42mm	Carton size: 464*357*372 mm			
Carton Quantity:	59PCS/Carton	Weight: 0.42Kg/PCS			





REMARKS:

- 1, The above mentioned data were measured at 230VAC input and 25°C.
- 2, Ripple & noise are measured at 20MHz of bandwidth by using a 12" twisted pair-wire terminated with a 0.1uf & 47uf parallel capacitor.
- 3, Cut the AC input before checking any mal-phenomenons.
- 4, Make sure the INPUT&OUPUT were in right situation before connected to power supply.
- 5, Be ware of high power pressure may caused by short circut when installing metal casing products.
- 6, Please contact us at info@xinrealpower.com for further solution if any unforeable problem happens.

Tel: 086 755 2306 0905

Fax: 086 755 2304 1269

Website: www.xinrealpower.com

Add: 5th Floor, B3 Building, Huafeng Shiji Industrial park, Hangcheng Road, Xixiang, Bao'an district, Shenzhen P.R.C.