



FEATURES

- •100% full load burn-in test
- Universal AC input
- •Small size and high efficiency
- •Conform to EMC EN5502 GB9254
- •Built-in EMI filter with tiny ripple
- •Comply with the safety standards UL60950 GB4943 EN60850
- Protection: short circuit/over Voltage/over/load temperature

MODEL		12V 250W 24V 250W		
OUTPUT	DC VOLTAGE	12V	24V	
	RATED CURRENT	20A	10A	
	CURRENT RANGE	0~16.5A	0~8.3A	
	RATED POWER	250W	250W	
	RIPPLE& NOISE (MAX.)	120mVp-p	150mVp-p	
	VOLTAGE TOLERANCE	±1%	±1%	
	SETUP , RISE TIME	1000ms, 50ms/230VAC 1000ms,50ms/115VAC at full load		
	HOLD UP TIME(Typ.)	20ms/230VAC 16ms/115VAC at full load		
INPUT	VOLTAGE RANGE	85~132VAC/170~264VAC		
	FREQUENCY RANGE	47~63Hz		
	POWER FACTOR(Typ.)	PF>0.6/220VAC		
	EFFICIENCY(Typ.)	85%	86%	
	AC CURRENT(Typ.)	4.5A/115VAC 2.5A/230VAC		
	INRUSH CURRENT(Typ.)	40A/115VAC 55A/230VAC		
	SHORT CIRCUIT	protection type: recovers automatically after fault condition is removed		
PROTECTION	OVER LOAD	105~135% hiccup mode , auto-recovery		
PROTECTION	DC ADJ. RANGE	115%~135% Cut off the output , auto-recovery		
	WORKING TEMP	-20°C∼ +60°C		
ENVIRONMENT	WORKING HUMIDITY	20%~90%RH		
	STORAGE TEMP , HUMIDITY	-40℃~+85℃,10%~90%RH		
SAFETY&EMC	SAFETY STANDARDS	CE,ROHS		
	WITHSTAND VOLTAGE	I/P-O/P:1.5KVAC I/P-FG:1.5KVAC O/P-FG:0.5KVAC		
	EMC TESTING STANDARD	EN55015:2006;EN61547:1995+A1:2000;EN61000-3-2:2006;		
		EN61000-3-3:1995+A2:2005;EN61347-1:2001;EN61347-2-13:2006		

Tel: 086 755 2306 0905


Fax: 086 755 2304 1269


Add: 5th Floor, B3 Building, Huafeng Shiji Industrial park, Hangcheng Road, Xixiang, Bao'an district, Shenzhen P.R.C.



Mechanical Specification Terminal Assignment

Terminal Assignment				
Pin No.	Assignment	Pin No.	Assignment	
1	AC/L	4.5	DC OUTPUT-V	
2	AC/N	6.7	DC OUTPUT+V	
3	≟ FG			
			£.	
Dimension: 230*92*53mm		Carton size: 464*357*372 mm		
Carton Quantity	: 30PCS/Carton	Weight: 0.78kg/PCS		





REMARKS:

1, The above mentioned data were measured at 230VAC input and 25°C.

- 2, Ripple & noise are measured at 20MHz of bandwidth by using a 12" twisted pair-wire terminated with a 0.1uf & 47uf parallel capacitor.
- **3**, Cut the AC input before checking any mal-phenomenons.
- 4, Make sure the INPUT&OUPUT were in right situation before connected to power supply.
- 5, Be ware of high power pressure may caused by short circut when installing metal casing products.
- 6, Please contact us at sanpu@cnshanpu.com for further solution if any unforeable problem happens.

Tel: 086 755 2306 0905

Fax: 086 755 2304 1269

Website: www.xinrealpower.com

Add: 5th Floor, B3 Building, Huafeng Shiji Industrial park, Hangcheng Road, Xixiang, Bao'an district, Shenzhen P.R.C.